

# CITY OF GENEVA IEPA Facility #IL0890350 2015 Annual Drinking Water Quality Report

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water. This report includes drinking water facts and contaminants detected in your drinking water supply during calendar year 2015. Each year, we will provide you a new report. If you need help understanding this report or have general questions, please contact the person listed below.

Contact Name: <u>Mike Martens</u>
Telephone Number: <u>630-232-1551</u> ext. <u>3103</u>

Este informe contiene informacion muy importante Sobre el aqua que usted bebe. Traduzcalo o hable con alquien que lo entienda bien.

Before we begin listing our unique water quality characteristics, here are some important facts you should know to help have a basic understanding of drinking water in general.

#### Sources of Drinking Water

Our source of water comes from: Groundwater Wells

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and groundwater wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic system, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial
  processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic
  systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800)426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, person who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water hotline (800) 426-4791.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

#### Source Water Assessment Information

Well 8 (00345), Well 9 (00584), Well 10 (00961), Well 11 (01681) utilize a sand and gravel aquifer. Well 6 (20044), Well 12 (01682), Well 13 (01683) utilize a deep bedrock aquifer.

#### Source Water Assessment Summary

We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to attend any of our regularly scheduled City Council meetings on the 1<sup>st</sup> and 3<sup>rd</sup> Monday of each month. The source water assessment for our water supply has been completed by the Illinois EPA. If you would like a copy of this information, please call our Water Supply and Distribution Supervisor Mike Martens at 630-232-1551 ext. 3103. To view a summary version of the completed Source Water Assessments, including: Importance of Source Water; Susceptibility to Contamination Determination; and documentation / recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl.

Based on information obtained in a Well Site Survey, published in 1992 by the Illinois EPA, sixty potential source or possible problem sites were identified within the survey of the Geneva's wells. Furthermore, information provided by the Leaking Underground Storage Tank and Remedial Project management Sections of the Illinois EPA indicated several additional sites with ongoing remediation which may be of concern. The Illinois EPA has determined that the source water obtained from Geneva Community Water Supply Wells #6, #12, and #13 are not susceptible to contamination. However, the source water obtained from Wells #8, #9, #10, and #11 are susceptible to contamination. This determination is based on a number of criteria including: monitoring conducted at the wells; monitoring conducted at the entry point to the distribution system; and the available hydrogeologic data on the wells.

## 2015 Regulated Contaminants Detected -Definition of terms-

AL	Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Avg	Regulatory compliance with some MCLs is based on running annual average of monthly samples.
MCL	Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water.  MCLs are set as close to the Maximum Contaminant Level Goal as feasible using the best available treatment technology.
MCLG	Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MRDL	Maximum Residual disinfectant Level: The highest level of disinfectant allowed in drinking water.
MRDLG	Maximum Residual Disinfectant Level Goal: The level of disinfectant in drinking water below which there is no know or expected risk to health. MRDLGs allow for a margin of safety.
N/A	Not Applicable
NTU	Nephelometric Turbidity Units.
pCi/L	Picocuries per liter ( a measure of radioactivity)
ppb	Parts per billion or micrograms per liter (ug/L) - or one ounce in 7,350,000 gallons of water.
ppm	Parts per million or milligrams per liter (mg/L) - our one ounce in 7,350 gallons of water,
RDL	Representative Detection Level

### City of Geneva - 2015 Water Quality Data IEPA #IL0890350

Lead	Lead	Collection	Lead	# Sites	Copper	Copper	Copper	# Sites	Violation	Likely
MCLG	Action	Date	90th	Over	MCLG	Action	90th	Over		Source of
	Level		Percential	Lead		Level	Percentile	Copper		Contaminant
	(AL)			(AL)		(AL)		(AL)		
0	15 ppb	7/25/2014	5.03	0	0	1.3 ppm	0	0	NO	Corrosion of household plumbing systems; Erosion of natural deposits.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. City of Geneva is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <a href="http://www.epa.gov/safewater.lead">http://www.epa.gov/safewater.lead</a>

Disinfectants & Disinfection By- Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contaminant
Chlorine	2015	1.11	.40 - 1.11	MRDLG =4	MRDL =4	ppm	No	Water additives to control microbes
Haloacetic Acids	2015	1.61	1.43 - 1.61	N/A	60	ppb	No	By-product of drink- ing water chlorination
TTHMs [Total Trihalomethanes]	2015	10.15	7.29 - 10.15	N/A	80	ppb		By-product of drink- ing water chlorination

Coliform Bacteria										
	T . 10 %	Highest Fecal Coliform or		Total number of		Likely				
MCLG	Total Coliform	number of	E.Coli MCL	positive Fecal	Violation	Source of				
WICEG	MCL	positive		Coliform or	Violation	Contaminant				
		samples		E.Coli samples						
	0 positive monthly samples		Fecal Coliform or E.Coli			Naturally present				
			MCL: A routine sample			in the environment				
		0	and repeat sample are			and are used as an				
0			total coliform positive,	0		indicator that other,				
			and one is also fecal	li i		potentially-harmful,				
			coliform or E. Coli			bacteria may be				
			positive			present.				

Inorganic Contaminants	Collection Date	Highest Level Detected	Ranges of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contaminant
Barium	2015	0.048	0.048	2	2	ppm	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural Deposits
Flouride	2015	1.14	.76 - 1.14	4	4	ppm	No	Erosion of natural deposits; Water add itive which promotes strong teeth; Fertil izer discharge
Cyanide	2015	Non Detected	0	200	200	ppb	No	Discharge from plast ic and fertilizer facto ries; Discharge from steel/metal factories
Hexavalent Chromium	2012	Non Detected	0	0.1	0.1	ppm	No	Discharge from steel and pulp mills, eros ion of natural depos its of chromium-3
Nitrate (measured as nitrogen)	2015	Non Detected	0	10	10	ppm	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Inorganic	Collection	Highest	Ranges of					Likely
Contaminants	Date	Level	Levels	MCLG	MCL	Units	Violation	Source of
		Detected	Detected					Contaminant
Combined	2015	0.82	.8282	0		pCi/L	No	Erosion of natural
Radium 226/228	2013	0.62	.0202	U	ر	pci/L	NU	deposits
Gross Alpha	2015	0.79	.7979	0	15	pCi/L	No	Erosion of natural
Emitters	2015	0.79	./5/9	U	13	pci/L	140	deposits

State	Collection	Highest	Ranges of					Likely	
Regulated	Date	Level	Levels	MCLG	MCL	Units	Violation	Source of	
Contaminants		Detected	Detected					Contaminant	
Iron	2015	0.05	0.0005	N/A	1	nnm	No	Erosion from natural	
Iron	2015	0.05	0.0005	IN/A	1	ppm	NO	ly occuring deposits.	
This contaminant is not currently regulated by USEPA. However, the state has set an MCL for this contaminant									
for supplies serving	for supplies serving a population of 1000 or more.								
Manganasa	2015	0.06	.00506	N/A	0.15	ppm	No	Erosion from natural	
Manganese								ly occuring deposits.	
This contaminant is	s not currer	ntly regulate	d by USEPA. How	ever, the	state has s	et an MO	L for this o	contaminant	
for supplies serving	g a populati	on of 1000 d	or more.			_			
								Erosion from natural	
Codium*	2015	16.0	16.0	NI/A	N/A		No	ly occuring deposits.	
Sodium*	2015	16.9	16.9	N/A		ppm	1 0	Used in water softener	
								regeneration	

There is not a state or federal MCL for sodium. Monitoring is required to provide information to consumers and health officials that are concerned about sodium intake due to dietary precautions. If you are on a sodium-restric ted diet, you should consult a physician about this level of sodium in the water.

Unregulated Contaminant Monitoring Rule3 (UCMR 3)	Collection Date	Results	Representative Detection Level (RDL)	Units	Violation	Likely Source of Contaminant
Chlorate	2015	110	20.0	ppb	No	Agricultural defoliant, disinfection byproduct
Strontium	2015	138.3	3.0	ppb	No	Naturally occuring element, historically used in glass of cathode-ray tube t.v.'s
Vanadium	2015	Non Detected	0.2	ppb	No	Naturally occuring element, can be added to steel or aluminum for strength
Chromium	2015	0.2	0.2	ppb	No	Naturally occuring element, used in making steel alloys, chrome plating
Cobalt	2015	Non Detected	1.0	ppb	No	Naturally occuring element, found in most rocks, soil, plants, and animals
Molybdenum	2015	Non Detected	1.0	ppb	No	Naturally occuring element, found in ores and present in plants, animals
Chromium (VI)	2015	Non Detected	0.03	ppb	No	Naturally occuring element, used in making steel alloys, chrome plating
1,4-Dioxane	2015	Non Detected	0.07	ppb	No	Used as a solvent in the manufacture of paper, textile products

Unregulated contaminants are those for which the EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist the EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted. A maximum contaminant level (MCL) for these substances has not been established by either state or federal regulations, nor has mandatory health effects language.